



Compliance Statement

No. 2017-835

Data communication cable, Category 7_A

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Product description

Screened cable (S/FTP) characterised up to 1000 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall braid screen
Flame retardant, halogen free

Product identification

100-910
100-911

Generic cabling and cabling components standards - Category 7_A cable requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 61156-5:2012 (Ed. 2.1)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- EN 50288-9-1:2012

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-1:2011 (Ed. 3.0) / IEC 60754-2:2011 (Ed. 2.0)
- IEC 61034-1:2013 (Ed. 3.1) / IEC 61034-2:2013 (Ed. 3.1)

Technical report

DELTA-T734873, DANAK-19/18411

EC Cabling product ID

5570

CS valid until

19 October 2018

This product has been tested by DELTA EC Cabling Group and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 17 October 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venlighedsvej 4 Tel. +45 72 19 40 00
2970 Hørsholm Fax +45 72 19 40 01
Denmark www.madebydelta.com/cable

