



Compliance Statement

No. 2017-1025

Data communication cable, Category 6

Company

Excel
Excel House
Junction Six Industrial park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Product description

Screened cable (F/UTP) characterised up to 350 MHz*
Horizontal floor wiring cable, 100 Ω
4 and 2x4 twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification

100-076 Excel Category 6 F/UTP Foil Cable LS0H
100-077 Excel Dual Category 6 F/UTP Foil cable LS0H

Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 61156-5:2012 (Ed. 2.1)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- EN 50288-5-1:2013
- ANSI/TIA-568-C.2:2009

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-1:2011 (Ed. 3.0) / IEC 60754-2:2011 (Ed. 2.0)
- IEC 61034-1:2013 (Ed. 3.1) / IEC 61034-2:2013 (Ed. 3.1)

Technical report

DELTA-T737831, DANAK-19/18698

EC Cabling product ID

5444

CS valid until

9 January 2019

This product has been tested by DELTA EC Cabling Group and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 18 December 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venlighedsvej 4 Tel. +45 72 19 40 00
2970 Hørsholm Fax +45 72 19 40 01
Denmark www.madebydelta.com/cable

